TITLE:

Input variable scaling for statistical modeling

AUTHOR(S):

Kim, Sanghong; Kano, Manabu; Nakagawa, Hiroshi;
Hasebe, Shinji

CITATION:

Kim, Sanghong ...[et al]. Input variable scaling for statistical modeling.
Computers & Chemical Engineering 2015, 74: 59-65

ISSUE DATE:

2015-03

URL:

<http://hdl.handle.net/2433/193671>

RIGHT:

© 2015 Elsevier Ltd.; This is not the published version. Please cite only the published version.; この論文は出版社版ではありません。引用の際には出版社版をご確認ご利用ください。

Input Variable Scaling for Statistical Modeling

Sanghong Kim^{a,*}, Manabu Kano^b, Hiroshi Nakagawa^c, Shinji Hasebe^a

^a*Dept. of Chemical Engineering, Kyoto University, Kyoto 6158510, Japan*

^b*Department of Systems Science, Kyoto University, Kyoto, 6068501, Japan*

^c*Formulation Technology Research Laboratories, Daiichi Sankyo Co., Ltd., Hiratsuka 2540014, Japan*

Abstract

Input variable scaling is one of the most important steps in statistical modeling. However, it has not been actively investigated, and autoscaling is mostly used. This paper proposes two input variable scaling methods for improving the accuracy of soft sensors. One method statistically derives the input variable scaling factors; the other one uses spectroscopic data of a material whose content is estimated by the soft sensor. The proposed methods can determine the scales of the input variables based on their importance in output estimation. Thus, it can reduce the negative effects of input variables which are not related to an output variable. The effectiveness of the proposed methods was confirmed through a numerical example and industrial applications to a pharmaceutical and a distillation processes. In the industrial applications, the proposed methods improved the estimation accuracy by up to 63% compared to conventional methods such as autoscaling with input variable selection.

Keywords: Statistical model, Soft sensor, Input variable scaling, Pharmaceutical process, Distillation process

1. Introduction

In the process industry, one of the most important tasks is to ensure quality and to reduce operating cost. However, real-time measurement of product quality is not always available due to unacceptable measurement equipment cost and long measurement time. To solve this problem, research on soft sensors,

*Corresponding author. Tel.: +81-(0)75-383-2677; fax: +81-(0)75-383-2677.

Email address: kim@cheme.kyoto-u.ac.jp (Sanghong Kim)

6 which estimate product quality using real-time measurements, has been actively
7 conducted (Kadlec et al., 2009; Kano and Fujiwara, 2013; Oh et al., 2013;
8 Khatibisepehr et al., 2014). According to a questionnaire survey (Kano and
9 Fujiwara, 2013), in 2009 soft sensors were working in over 400 distillation and
10 chemical reaction processes at 15 companies in Japan. In addition, soft sensors
11 have recently attracted much interest in the pharmaceutical industry to achieve a
12 new quality assurance system composed of Quality by Design (QbD) and process
13 analytical technology (PAT) (Roggo et al., 2007; Rajalahti and Kvalheim, 2011).
14 Building a soft sensor requires many steps such as data acquisition, abnormal data
15 detection, data preprocessing, input variable selection, model building, and model
16 validation. Although input variable scaling, a data preprocessing method in which
17 the values of each input variable are multiplied by the scaling factor of the input
18 variable, can have significant effect on the estimation performance of soft sensors,
19 research on input variable scaling has not been actively conducted. Hence, this
20 paper focuses on input variable scaling, which is mathematically represented as

$$\tilde{\mathbf{X}} = \mathbf{X}\mathbf{\Lambda} \quad (1)$$

$$\mathbf{\Lambda} = \text{diag}(\lambda_1, \lambda_2, \dots, \lambda_M) \quad (2)$$

21 where $\mathbf{X} \in \mathbb{R}^{N \times M}$ is the raw input variable matrix, in which the input variables
22 are not scaled, $\tilde{\mathbf{X}} \in \mathbb{R}^{N \times M}$ is the scaled input variable matrix, λ_m is a nonnegative
23 input variable scaling factor for the m -th input variable, N is the number of
24 samples, and M is the number of input variables. It is assumed that the mean of
25 each input variable is zero without loss of generality. The input variable scaling
26 affects important statistical properties of the data such as the distance between
27 samples and the covariance of samples. It also affects the estimation result.
28 For example, the m -th input variable x_m cannot have any influence on output
29 estimation when λ_m is zero. Thus, $\mathbf{\Lambda} \in \mathbb{R}^{M \times M}$ should be carefully selected to
30 create accurate soft sensors.

31 In past research, autoscaling was commonly used (Engel et al., 2013; van den
32 Berg et al., 2006; Todeschini et al., 1999). In addition, Pareto scaling, level
33 scaling, poisson scaling, range scaling, and VAST scaling (Keun et al., 2003)

34 have been considered. The scaling factors in these methods are defined as

$$\frac{1}{\lambda_m} = \begin{cases} \sigma_m & (\text{autoscaling}) \\ \sqrt{\sigma_m} & (\text{pareto scaling}) \\ \bar{x}_m & (\text{level scaling}) \\ \sqrt{\bar{x}_m} & (\text{poisson scaling}) \\ x_{m,\max} - x_{m,\min} & (\text{range scaling}) \\ \frac{\sigma_m^2}{\bar{x}_m} & (\text{VAST scaling}) \end{cases} \quad (3)$$

35 where σ_m is the standard deviation of x_m , $\bar{x}_m$ is the mean value of x_m , $x_{m,\max}$ is
36 the maximum value of x_m , and $x_{m,\min}$ is the minimum value x_m . These methods
37 define the input variable scaling factors based only on the information from the
38 input variables such as their standard deviations and means. Hence, input variable
39 scaling factors can be large for the input variables which are irrelevant to the
40 output variable when these method are used, and the estimation performance
41 of soft sensors may deteriorate. Some of the irrelevant input variables might
42 be removed by using input variable selection methods such as the stepwise
43 method (Hocking, 1976), variable influence on projection (VIP) (Wold et al.,
44 2001) and least absolute shrinkage and selection operator (LASSO) (Tibshirani,
45 1996). It is, however, very difficult to remove all irrelevant input variables
46 without removing any relevant input variables, and some irrelevant input variables
47 generally remain after input variable selection. Thus, it is needed to determine the
48 input variable scaling factors according to the importance of the input variables
49 in output estimation. To take into account the importance of input variables
50 in the output estimation, Kuzmanovski et al. (Kuzmanovski et al., 2009) used
51 the genetic algorithm to optimize the input variable scaling factor. However,
52 the computational burden of the genetic algorithm is considerable. Martens et
53 al. (Martens et al., 2003) proposed to use the magnitude of the undesired signals
54 in measurements to determine the input variable scaling factors. But, this method
55 is applicable only to spectroscopic data. To solve the above-mentioned problems,
56 two input variable scaling methods are proposed. The proposed methods can
57 determine the input variable scaling factors based on the importance of input
58 variables in output estimation with short computational time. One of the proposed
59 methods can be applied to any data.

60 2. Input variable scaling methods

61 Conventional input variable scaling methods such as autoscaling and range
62 scaling do not determine the input variable scaling factors based on the importance
63 of individual input variables in output estimation. These methods, therefore, can
64 cause overfitting especially when the number of samples is small. One can reduce
65 the effect of irrelevant input variables on output estimation by assigning small
66 input variable scaling factors to those input variables. On the other hand, large
67 input variable scaling factors should be assigned to input variables which have a
68 large influence on an output variable.

69 We propose two methods to evaluate the influence of each input variable on
70 an output variable and assign appropriate input variable scaling factors to input
71 variables. The first one statistically derives the input variable scaling factors, while
72 the second one uses spectroscopic data of a material whose content is estimated
73 by a soft sensor.

74 2.1. Proposed method 1: data-based approach

75 Proposed method 1 statistically calculates the input variable scaling factor in
76 an iterative manner. In this paper, the standardized regression coefficients of input
77 variables in a partial least squares (PLS) model and the VIP scores are used as the
78 input variable scaling factor, since they correlate to the importance of each input
79 variable. The standardized regression coefficient is defined as the product of the
80 regression coefficient β and the standard deviation σ of an input variable. The
81 algorithm of proposed method 1 is as follows:

- 82 1. Prepare the raw input variable matrix $\mathbf{X}$ and an output variable vector $\mathbf{y} \in \mathbb{R}^N$.
- 83
- 84 2. Set the iteration number i to 1 and the maximum iteration number to I .
- 85 3. Calculate the input variable scaling factor matrix $\Lambda_0 =$
86 $\text{diag}(\lambda_{10}, \lambda_{20}, \dots, \lambda_{M0})$ where λ_{m0} is $1/\sigma_{m0}$. Here, σ_{m0} is the standard
87 deviation of the m -th input variable ($m = 1, 2, \dots, M$) in the raw input
88 variable matrix $\mathbf{X}$.
- 89 4. Let the scaled input matrix $\tilde{\mathbf{X}}_0 = \mathbf{X}\Lambda_0$.
- 90 5. Calculate the new input variable scaling factor matrix

$$\Lambda_i = \text{diag}(\lambda_{1i}, \lambda_{2i}, \dots, \lambda_{Mi}) \quad (4)$$

$$\lambda_{mi} = \begin{cases} |\beta_{mi}| \sigma_{mi} & (\text{standardized regression coefficient}) \\ \text{VIP}_{mi} & (\text{VIP score}) \end{cases} \quad (5)$$

- 91 for every m . Here, β_{mi} , σ_{mi} and VIP_{mi} denote the regression coefficient, the
92 standard deviation and VIP score of the m -th input variable obtained using
93 the scaled input matrix $\tilde{\mathbf{X}}_{i-1}$ and the output variable vector $\mathbf{y}$, respectively.
94 6. Calculate the new scaled input matrix $\tilde{\mathbf{X}}_i = \mathbf{X} \Lambda_i$.
95 7. Finish the calculation if $i = I$. Otherwise set $i = i + 1$ and go to step 5.

96 Steps 3 and 4 in the above algorithm correspond to autoscaling. In step 5, the
97 input variable scaling factors are updated, and the input variable matrix is updated
98 in step 6. The explicit expression of the regression coefficient in a PLS model and
99 the VIP score is available in section 4.2 of (Kim et al., 2013). The convergence
100 of this method is not guaranteed in all cases. However, the values of regression
101 coefficients converged in most cases at least in the case studies conducted in this
102 paper as shown in the next section.

103 The regression coefficient vector obtained by PLS is represented as

$$\beta_{\text{PLS}} = \mathbf{W}(\mathbf{P}^T \mathbf{W})^{-1} \mathbf{q} \quad (6)$$

$$\mathbf{W} = [\mathbf{w}_1, \mathbf{w}_2, \dots, \mathbf{w}_R] \quad (7)$$

$$\mathbf{P} = [\mathbf{p}_1, \mathbf{p}_2, \dots, \mathbf{p}_R] \quad (8)$$

$$\mathbf{q} = [q_1, q_2, \dots, q_R]^T \quad (9)$$

104 where $\mathbf{w}_r$, $\mathbf{p}_r$ and q_r are the weight vector, the loading vector of the input variable
105 and the regression coefficient for the r -th latent variable.

106 The VIP score (Wold et al., 2001) of the m -th variable is defined as

$$VIP_m = \sqrt{\frac{M \sum_{r=1}^R \left[(q_r^2 \mathbf{t}_r^T \mathbf{t}_r) \left(\frac{w_{mr}}{\|\mathbf{w}_r\|} \right)^2 \right]}{\sum_{r=1}^R (q_r^2 \mathbf{t}_r^T \mathbf{t}_r)}} \quad (10)$$

107 where w_{mr} is the m -th component of the r -th weight vector $\mathbf{w}_r$. $\mathbf{t}_r$ is the r -th
108 latent variable score.

109 2.2. Proposed method 2: knowledge-based approach

In the pharmaceutical and food industries, soft sensors are often used to estimate the content of an important material from the spectroscopic data of products (Cen and He, 2007; Roggo et al., 2007; Jamragiewicz, 2012). In such a situation, it is crucial to identify the important variables/wavelengths.

A large number of statistical wavelength selection methods have been proposed (Jouen-Rimbauda and Massart, 1995; Nørgaard et al., 2000; Jiang et al., 2002; Kim et al., 2011; Fujiwara et al., 2012). These methods, however, may not work well when the number of samples is small. In addition, they have tuning parameters, which are difficult to determine. To solve this problem, this paper proposes a knowledge-based input variable scaling method using the spectrum of the important material, in which the input variable scaling factor λ_m is defined as

$$\lambda_m = \frac{|\xi_m|}{\sigma_{x_m}} \quad (11)$$

where ξ_m is the (preprocessed) spectrum signal of an important material at the m -th wavelength and σ_{x_m} is the standard deviation of the (preprocessed) spectrum signal at the m -th wavelength in the raw input variable matrix $\mathbf{X}$. Here, the spectrum signals of the important material and the products might be preprocessed before the input variable scaling factor is calculated. For example, the Savitsky-Golay filter (Savitzky and Golay, 1964) and standard normal variate (SNV) (Barnes et al., 1989) can be used.

This method is based on the idea that the wavelengths where the ratio λ_m is small are not important for soft-sensor design, because they have low signal-to-noise ratios and the (preprocessed) spectrum signal of the products would not significantly change with the amount of the important material at those wavelengths. Proposed method 2 is free from parameter tuning and uses process knowledge. Thus, it is expected to achieve higher estimation performance especially when the number of samples is small compared to proposed method 1, which uses only statistical information of the process data.

3. Illustrative numerical example

In this section, an illustrative numerical example is shown to confirm that input variable scaling can have significant influence on the estimation accuracy of soft sensors and that proposed method 1 can improve estimation accuracy.

3.1. Problem setting

In this example, the number of input variables x_m is 30 and the number of output variable y is 1. Input and output variables are the sum of real values of

132 state variables s_m and measurement noises w_m , which are defined as follows.

$$w_m \sim N(0, 0.005^2) \quad (m = 0, 1, \dots, 30) \quad (12)$$

$$s_m \sim \text{rand}(0, 1) \quad (m = 1, 2, \dots, 30) \quad (13)$$

$$x_m = s_m + w_m \quad (14)$$

$$y = s_1 + 3s_2 + 5s_3 + w_0 \quad (15)$$

133 Here, $N(\mu, \sigma^2)$ denotes the normal distribution whose mean is μ and standard
134 deviation is σ , and $\text{rand}(a, b)$ denotes the uniform random distribution on the open
135 interval from a to b . w_m and s_m are independent from each other. x_m and y are
136 the measurements used for soft-sensor design while s_m and w_m are not measured.

137 In this example, only three input variables (x_1 - x_3) are related to the output
138 variable and the input-output relationship is linear. The other 27 variables
139 (x_4 - x_{30}), which are not related to the output variable, are used for model
140 building. Thus, the probability of chance correlation could be high when the
141 number of samples for model building is small. Input variable selection methods
142 were not used to check whether input variable scaling can reduce the risk of
143 chance correlation when irrelevant variables cannot be removed by input variable
144 selection.

145 From Equations (12)-(15), 15 samples are generated and used for model
146 building. The number of samples is realistic since it is usual that the number
147 of samples is much smaller than that of input variables when spectroscopic data
148 is used for soft-sensor design. For example, the number of samples for model
149 building is 9 or 45, and the number of input variable is 1868 in the example
150 described in Section 4.1. To validate the soft sensor built using the 15 samples,
151 3000 samples are independently generated and used as model validation data. It
152 should be noted that 3000 samples are used just for model validation and not
153 available when the soft sensor is built. In addition, because w_m and s_m are
154 randomly determined and their values affect estimation performance, 1000 sets
155 of model building and validation data are generated and each dataset was used
156 separately.

157 For soft-sensor design, PLS was used with one of the following input variable
158 scaling methods:

- 159 1. Autoscaling.
- 160 2. A reference method in which $\lambda_m = 1$ ($m = 1, 2, 3$) and $\lambda_m = 0.1$ ($m =$
161 $4, 5, \dots, 30$).
- 162 3. Proposed method 1 with different maximum iteration numbers $I = 1, 3$ and
163 5.

164 In the reference method, larger input variable scaling factors are assigned to
165 x_1 - x_3 than x_4 - x_{30} . It should be noted that the reference method cannot be
166 used in real situations because the importance of each input variable is generally
167 unknown. The number of the latent variables for each PLS model is determined
168 by leave-one-out cross-validation.

169 3.2. Results and discussion

170 The model validation results for 1000 sets of model building and validation
171 data are shown in Figure 1. Comparing autoscaling and the reference method
172 confirms that the estimation accuracy can be greatly improved by properly setting
173 the input variable scaling factors. In addition, proposed method 1 successfully
174 reduced average of the root mean square error (RMSE) for the validation data as
175 well as the reference method. Proposed method 1 had higher standard deviation of
176 the RMSE than the reference method. This is because the standardized regression
177 coefficients and the VIP scores do not always accurately represent the importance
178 of the input variables when they are obtained from only 15 samples. Figure 2
179 shows an example of the change of the regression coefficients for input variables
180 before input scaling in a model building data. The values at iteration number 0
181 are those obtained by autoscaling. The convergence is not guaranteed in all cases.
182 However, the values of regression coefficients converged in most cases at least in
183 the case studies conducted in this paper as shown in Figure 2.

184 In this example, smaller RMSE was obtained by using VIP scores than using
185 the standardized regression coefficients, but the difference is not significant and
186 using the standardized regression coefficients might be better in another example.
187 The method for selecting the best statistical index is outside the scope of this
188 research.

Figure 1: Model validation result for 1000 datasets in the numerical example.

Figure 2: Change of regression coefficients for input variables before input scaling with the iteration number.

189 4. Industrial application

190 4.1. Pharmaceutical process

191 In the pharmaceutical industry, it is required to measure the amount of residual
192 drug substances in manufacturing equipment after cleaning for product quality
193 assurance and safety. Soft sensors are useful for achieving rapid and low-cost
194 measurement of the amount of residual drug substances. In this paper, soft sensors
195 were built to estimate the amount of magnesium stearate, which is a standard
196 excipient in tablets, using the infrared spectrum of the methanol solution for
197 different magnesium stearate concentrations. The overview of the experimental
198 data is shown in Table 1. The absorbance spectra were measured at 400-4000
199 cm^{-1} . The spectra were secondary differentiated to reduce the effect of baseline
200 shift. Secondary differentiation was applied also to the spectrum of magnesium
201 stearate. The differentiated spectra of magnesium stearate and the methanol
202 solutions of different magnesium stearate concentrations are shown in Figure 3.
203 The magnesium stearate spectrum is scaled so that the spectral peaks can be
204 clearly seen. More detailed information about the materials and experimental
205 condition is described in Nakagawa et al. (Nakagawa et al., 2012).

206 In this case study, no scaling, autoscaling, and the proposed methods were
207 compared. No scaling and autoscaling were applied with two popular statistical
208 wavelength selection methods, *i.e.* VIP and LASSO. On the other hand, all
209 wavelengths were used when the proposed methods were applied. From Table 1,
210 the data from runs 1-9 was used for model building; 10-15 for parameter tuning;
211 and 16-21 for model validation. To evaluate the influence of the number of
212 samples on estimation accuracy, a different number of the model building and
213 parameter tuning samples were used in cases 1 and 2. In case 1, one sample was
214 randomly selected from each of runs 1-15, and 9 samples from runs 1-9 were for
215 model building and 6 samples from runs 10-15 were used for parameter tuning.
216 To evaluate the influence of sample selection on estimation performance, 100 sets
217 of model building and parameter tuning data were independently generated. In
218 case 2, all samples were used. Table 2 shows the model validation results. For
219 case 1, the median, top 25th percentile (first quartile) and bottom 25th percentile
220 (third quartile) of the RMSEs obtained from the 100 sets used for model building
221 and parameter tuning data are shown. Tuning parameters such as the number
222 of the latent variables in PLS models and the thresholds in VIP and LASSO were
223 determined by trial and error so as to minimize the RMSE for the parameter tuning
224 data. In proposed method 1 using VIP score, 5 latent variables were selected, and
225 the iteration number i was determined as 5. The proposed methods gave 12-63%

226 smaller RMSE for model validation data than the conventional input variable
227 scaling methods even when wavelength selection was conducted using VIP and
228 LASSO. Figure 4 shows the VIP score for different number of iterations i . The
229 VIP score with $i = 1$ was used for wavelength selection in method 5, and that with
230 $i = 5$ was used as input scaling factor in method 8. By the iterative calculation
231 of the VIP score, important variables around 2800 and 1500 nm are emphasized,
232 and the estimation performance was improved.

233 The above results clearly demonstrate the effectiveness of the proposed
234 methods; even without variable selection they were able to reduce the estimation
235 error. Proposed method 2 had about 10% smaller RMSE than proposed method
236 1 in case 1, where the number of samples used for model building and parameter
237 tuning is small. This result confirms that process knowledge is helpful for input
238 variable scaling and can contribute to improve estimation performance.

Table 1: Experimental data for estimation of magnesium stearate concentration.

Run number	Magnesium stearate concentration [$\mu\text{g}/\text{cm}^2$]	Number of samples
1	0.08	5
2	0.20	5
3	0.40	5
4	0.80	5
5	1.20	5
6	1.60	5
7	2.88	5
8	3.20	5
9	4.00	5
10	0.12	5
11	0.24	5
12	0.40	5
13	0.80	5
14	1.20	5
15	1.60	5
16	0.16	5
17	0.32	5
18	0.40	5
19	0.80	5
20	1.20	5
21	1.60	5

Figure 3: Spectra of magnesium stearate and methanol solutions at different magnesium stearate concentrations.

Figure 4: VIP score for the different iteration numbers.

Table 2: Results of the case study in the pharmaceutical process.

Method	Scaling	Wavelength selection	Model	RMSE	
				Case 1	Case 2
1	None	None	PLS	0.362 / 0.386 / 0.418	0.346
2	None	VIP	PLS	0.363 / 0.386 / 0.419	0.346
3	None	LASSO	LASSO	0.338 / 0.338 / 0.348	0.329
4	Autoscaling	None	PLS	0.277 / 0.285 / 0.295	0.200
5	Autoscaling	VIP	PLS	0.265 / 0.278 / 0.285	0.178
6	Autoscaling	LASSO	LASSO	0.239 / 0.273 / 0.301	0.156
7	Proposed method 1 (reg. coef.)	None	PLS	0.207 / 0.239 / 0.266	0.160
8	Proposed method 1 (VIP)	None	PLS	0.207 / 0.234 / 0.256	0.130
9	Proposed method 2	None	PLS	0.199 / 0.215 / 0.231	0.132

*reg. coef.: regression coefficient

239 4.2. *Distillation process*

240 In distillation processes, soft sensors are often used to estimate product
241 quality such as the concentration of impurities. Soft sensors were developed
242 to estimate the 95% distillation temperature, which is an important quality of
243 cracked gasoline. In the target process, the 95% distillation temperature is
244 usually measured once a day, and a soft sensor is needed to implement inferential
245 control of the 95% distillation temperature and to reduce the energy consumption.
246 Forty-nine input variables, including 24 temperatures, 17 flow rates, 3 densities,
247 2 pressures, and 3 liquid levels, were used for model building. Three hundred
248 samples were used for model building. Data for parameter tuning and model
249 validation both consisted of 100 samples. Tuning parameters such as the number
250 of the latent variables in the PLS model and the thresholds for input variable
251 selection were selected by trial and error so as to minimize the RMSE for the
252 parameter tuning data.

253 Figure 5 shows the model validation results. In this example, autoscaling and
254 proposed method 1 were compared. Proposed method 2 was not used since the
255 spectrum of the product was not available. The values of the 95% distillation
256 temperature were scaled so that the RMSE for model validation data of the
257 conventional method using autoscaling without input variable selection was 1. As
258 shown in Figure 5, proposed method 1 reduced the RMSE for model validation
259 data by about 30% compared to the method using autoscaling without variable
260 selection. As well, proposed method 1 using VIP scores reduced the RMSE by
261 about 10% compared to methods using autoscaling with VIP and LASSO. This
262 result confirmed the usefulness of proposed method 1.

Figure 5: Model validation result in the distillation process.

263 **5. Conclusions**

264 This paper on input variable scaling methods for soft-sensor design showed
265 that the input variable scaling factors should be determined on the basis of the
266 importance of input variables for output estimation. Two new input variable
267 scaling methods, which can evaluate the importance of input variables, were
268 proposed. One method statistically derives the input variable scaling factors. The
269 other one uses the spectroscopic data of a material whose content is an estimation
270 target. The effectiveness of the proposed methods was confirmed through their
271 application to a numerical example and industrial applications in a pharmaceutical
272 and a distillation processes. The proposed methods were able to develop up to
273 63% more accurate soft sensors compared to the conventional methods such as
274 autoscaling with variable selection methods.

References

- Barnes, R.J., Dhanoa, M.S., Lister, S.J., 1989. Standard normal variate transformation and de-trending of near-infrared diffuse reflectance spectra. *Appl. Spectrosc.* 43, 772–777.
- van den Berg, R.A., Hoefsloot, H.C.J., Westerhuis, J.A., Smilde, A.K., van der Werf, M.J., 2006. Centering, scaling, and transformations improving the biological information content of metabolomics data. *BMC Genomics* 7:142.
- Cen, H., He, Y., 2007. Theory and application of near infrared reflectance spectroscopy in determination of food quality. *Trends Food Sci. Technol.* 18, 72 – 83.
- Engel, J., Gerretzen, J., Szymańska, E., Jansen, J.J., Downey, G., Blanchet, L., Buydens, L.M., 2013. Breaking with trends in pre-processing? *Trends in Anal. Chem.* 50, 96 – 106.
- Fujiwara, K., Sawada, H., Kano, M., 2012. Input variable selection for PLS modeling using nearest correlation spectral clustering. *Chemom. Intell. Lab. Syst.* 118, 109–119.
- Hocking, R.R., 1976. A biometrics invited paper. the analysis and selection of variables in linear regression. *Biometrics* 32, pp. 1–49.
- Jamrógiewicz, M., 2012. Application of the near-infrared spectroscopy in the pharmaceutical technology. *J. Pharmaceut. Biomed.* 66, 1 – 10.

- Jiang, J.H., James, R., Siesler, B.H.W., Ozaki, Y., 2002. Wavelength interval selection in multicomponent spectral analysis by moving window partial least-squares regression with applications to mid-infrared and near-infrared spectroscopic data. *Anal. Chem.* 74, 3555–3565.
- Jouen-Rimbauda, D., Massart, D.L., 1995. Genetic algorithms as a tool for wavelength selection in multivariate calibration. *Anal. Chem.* 67, 4295–4301.
- Kadlec, P., Gabrys, B., Strandt, S., 2009. Data-driven soft sensors in the process industry. *Comput. and Chem. Eng.* 33, 795–814.
- Kano, M., Fujiwara, K., 2013. Virtual sensing technology in process industries: trends and challenges revealed by recent industrial applications. *J. Chem. Eng. Jpn.* 46, 1–17.
- Keun, H.C., Ebbels, T.M.D., Antti, H., Bollard, M.E., Beckonert, O., Holmes, E., Lindon, J.C., Nicholson, J.K., 2003. Improved analysis of multivariate data by variable stability scaling application to nmr-based metabolic profiling. *Anal. Chim. Acta* 490, 265–276.
- Khatibisepehr, S., Huang, B., Khare, S., Domlan, E., Xu, F., Espejo, A., Kadali, R., 2014. A probabilistic framework for real-time performance assessment of inferential sensors. *Control Engineering Practice* 26, 136 – 150.
- Kim, S., Kano, M., Hasebe, S., Takinami, A., Seki, T., 2013. Long-term industrial applications of inferential control based on just-in-time soft-sensors: Economical impact and challenges. *Ind. Eng. Chem. Res.* 52, 12346–12356.
- Kim, S., Kano, M., Nakagawa, H., Hasebe, S., 2011. Estimation of active pharmaceutical ingredients content using locally weighted partial least squares and statistical wavelength selection. *Int. J. Pharm.* 421, 269–274.
- Kuzmanovski, I., Novi, M., Trpkovska, M., 2009. Automatic adjustment of the relative importance of different input variables for optimization of counter-propagation artificial neural networks. *Anal. Chim. Acta* 642, 142–147.
- Martens, H., Hoy, M., Wise, B.M., Bro, R., Brockhoff, P.B., 2003. Pre-whitening of data by covariance-weighted pre-processing. *J. Chemom.* 17, 153–165.
- Nakagawa, H., Tajima, T., Kano, M., Kim, S., Hasebe, S., Suzuki, T., Nakagami, H., 2012. Evaluation of infrared-reflection absorption spectroscopy

- measurement and locally weighted partial least-squares for rapid analysis of residual drug substances in cleaning processes. *Anal. Chem.* 84, 3820–3826.
- Nørgaard, L., Saudland, A., Wagner, J., Nielsen, J.P., Munck, L., Engelsen, S.B., 2000. Interval partial least-squares regression (iPLS): A comparative chemometric study with an example from near-infrared spectroscopy. *Appl. Spectrosc.* 54, 413–419.
- Oh, S.K., Yoo, S.J., Jeong, D.H., Lee, J.M., 2013. Real-time estimation of glucose concentration in algae cultivation system using raman spectroscopy. *Bioresource Technology* 142, 131 – 137.
- Rajalahti, T., Kvalheim, O.M., 2011. Multivariate data analysis in pharmaceuticals: A tutorial review. *Int. J. Pharm.* 417, 280–290.
- Roggo, Y., Chalus, P., Maurer, L., Lema-Martinez, C., Edmond, A., Jent, N., 2007. A review of near infrared spectroscopy and chemometrics in pharmaceutical technologies. *J. Pharm. Biomed. Anal.* 44, 683–700.
- Savitzky, A., Golay, M.J.E., 1964. Smoothing and differentiation of data by simplified least squares procedures. *Anal. Chem.* 36, 1627–1639.
- Tibshirani, R., 1996. Regression shrinkage and selection via the lasso. *J. Roy. Statist. Soc. Ser. B* 58, 267–288.
- Todeschini, R., Consonni, V., Maiocchi, A., 1999. The k correlation index theory development and its application in chemometrics. *Chemom. Intell. Lab. Syst.* 46, 13–29.
- Wold, S., Sjöström, M., Eriksson, L., 2001. PLS-regression: a basic tool of chemometrics. *Chemom. Intell. Lab. Syst.* 58, 109 – 130.