TITLE:

Regulations and perspectives on disinfection by-products: importance of estimating overall toxicity

AUTHOR(S):

Itoh, Sadahiko; Gordon, Bruce A.; Callan, Philip; Bartram, Jamie

CITATION:

Itoh, Sadahiko ...[et al]. Regulations and perspectives on disinfection by-products: importance of estimating overall toxicity. Journal of Water Supply: Research and Technology--AQUA 2011, 60(5): 261-274

ISSUE DATE:

2011-08

URL:

<http://hdl.handle.net/2433/197442>

RIGHT:

©IWA Publishing 2011. The definitive peer-reviewed and edited version of this article is published in Journal of Water Supply: Research and Technology--AQUA Vol 60 No 5 pp 261-274 (2011) doi:10.2166/aqua.2011.068 and is available at www.iwapublishing.com; この論文は出版社版ではありません。引用の際には出版社版をご確認ください。 ; This is not the published version. Please cite only the published version.

Regulations and perspectives on disinfection by-products
- Importance of estimating overall toxicity

Sadahiko Itoh^a, Bruce A. Gordon^b, Philip Callan^c, Jamie Bartram^d

^aDepartment of Environmental Engineering, Kyoto University, C-1 Kyotodaigaku Katsura, Nishikyo, Kyoto 615-8540, Japan

^bAssessing and Managing Environmental Risks to Health, World Health Organization, 20 avenue Appia, 1211 Geneva 27, Switzerland

^cNational Health and Medical Research Council, GPO Box 1421, Canberra ACT 2601, Australia

^dGillings School of Global Public Health, The University of North Carolina at Chapel Hill, Rosenau 162B, 135 Dauer Drive, CB #7431, Chapel Hill 27599-7431, USA

Address correspondence to S. Itoh,
Tel.: +81-75-383-3254; fax: +81-75-383-3256.
E-mail: ito@urban.env.kyoto-u.ac.jp

Regulations and perspectives on disinfection by-products

ABSTRACT

Chemical disinfection of drinking-water results in the formation of disinfection by-products (DBPs). This paper reviews evidence on the overall toxicity of disinfected water instead of focusing on the effects of individual DBPs. The possible health effects of ingesting DBPs include development of cancer and adverse reproductive/developmental outcomes. Only a few of the 600-700 chlorinated-by-products are regulated, accounting for only a small portion of the overall toxicity of DBPs. This review showed that current water quality management, based on complying with standard values set for individual DBPs, is insufficient in responding to overall toxicity from DBP species. Because water suppliers typically focus their water quality management efforts on meeting the defined maximum concentration standards for individual regulated parameters, current water management practices may not adequately focus on effectively reducing overall DBP toxicity. Therefore, we recommend a progressive shift towards preventive and holistic DBP management based on a comprehensive health-based risk assessment that takes into account the overall toxicity and is supported by a validation of the control processes. We also present a prioritized research agenda that will help determine risk assessment and management and facilitate the development of regulations. This includes the development of an overall index for overall DBP toxicity.

Keywords carcinogenicity, disinfection by-products, drinking-water quality standards, reproductive/developmental toxicity

WEAKNESSES IN THE CURRENT REGULATORY APPROACHES ON DBPS

Trihalomethanes (THMs) were originally recognized as a potential health concern in drinking-water in the 1970s. Since then, there has been extensive effort by researchers internationally to detect and identify other disinfection by-products (DBPs) (Krasner *et al.* 1989; Stevens *et al.* 1990; Richardson 1998). Although THMs are the most commonly regulated DBP group, they only account for 20-30% of total organic halides (TOX) formed by chlorination. With advances in analytical technologies, 600-700 chlorinated by-products have now been identified. Despite these efforts, it is estimated that detectable by-products account for approximately 50% of TOX. Richardson *et al.* (2007) recently reviewed this issue focusing on carcinogenicity and genotoxicity of DBPs. In addition, the evidence to date has been considered adequate to set health-based values for less than 20 DBPs. As a matter of fact, a total of 18 DBPs currently have health-based values including provisional guideline values that have been derived by World Health Organization (2006), U.S. (U.S. Environmental Protection Agency 2006), European Union (1998), Canada (Health Canada 2007), and Japan (Council on Public Welfare Science 2003). No by-product has a health-based value that was determined to account for reproductive and developmental endpoints.

Internationally, current DBP-related regulations (World Health Organization 2006; Karanfil *et al.* 2008) address only a relatively small fraction of the overall DBP toxicity. This proportion cannot be easily increased by monitoring increased numbers of DBP species, because regulation and monitoring of more DBPs has both scientific and financial constraints. Therefore, efforts have focused on the overall toxicity of drinking-water.

Here we review the results of studies on the overall toxicity of disinfected water instead of focusing on individual DBPs. The toxicity described in this report includes not only carcinogenicity but also reproductive and developmental toxicity. First, this paper presents some evidence that demonstrates toxicity in disinfected water that cannot be attributed to the currently-regulated by-products. This confirms the importance of estimating the overall toxicity of drinking-water. Next, we review attempts to evaluate the overall toxicity of disinfected water using *in vivo* bioassays. We discuss problems with these assays and describe on-going research by the U.S. Environmental Protection Agency (US EPA). Finally, we highlight requirements of future drinking-water quality regulation and make recommendations.

EXAMPLES ILLUSTRATING THE IMPORTANCE OF ESTIMATING THE OVERALL TOXICITY OF DISINFECTED WATER

Regulations and perspectives on disinfection by-products

Contribution of individual by-products to the toxicity of chlorinated water

Some researchers have measured the concentrations of by-products and examined the toxicity of individual by-products by *in vitro* bioassays. **Table 1** shows an example obtained by Itoh & Echigo (2008). The chromosomal aberration test using Chinese hamster lung cells and the transformation test using mouse fibroblast cells were performed as indices to estimate the initiation and promotion, respectively, in the carcinogenesis process. Three by-products: chloroform, dichloroacetic acid (DCA), and trichloroacetic acid (TCA), contributed 2.9% of the chromosomal aberration-inducing activity and 1.4% to the transformation efficiency. The contributions of MX (3-chloro-4-(dichloromethyl)-5-hydroxy-2(5H)-furanone) and bromate ion were almost negligible (less than 0.1%).

Previous research has also reported that individual DBPs make small contributions to overall mutagenicity, as reviewed by Donald *et al.* (1989). Meier *et al.* (1985) estimated that the summed mutagenicity of ten chlorinated by-products was only 7-8% on TA100 and less than 2% on TA98 by the Ames test. Research using the Ames test has shown that MX contributes from 0.2 to 60 percent of the mutagenicity of chlorinated water (Kronberg *et al.* 1988; Kinae *et al.* 2000). On the other hand, the contribution of MX to mutagenicity assessed by the Ames test and by a test using cultured mammalian cells differ. Plewa *et al.* (2002) measured the DNA-damaging activity of several DBPs and MX by alkaline single-cell gel electrophoresis (SCGE, comet assay) using CHO cells. This assay indicated that the genotoxicity of MX was very weak compared to that of bromoacetic acid. This is because MX has high affinity for protein and other nucleophiles to reduce its genotoxicity in mammalian cells. Thus, an estimate of MX based on the result of the Ames test may overestimate its cancer risk (McDonald & Komulainen 2005).

It is widely known that the individual by-products analyzed in these studies account for a small proportion of the overall genotoxicity of chlorinated water and the toxicity of chlorinated water can be attributed predominantly to by-products other than those currently regulated. The overall toxicity measured by *in vitro* and *in vivo* bioassays is discussed in ***in vitro* mutagenicity testing** and ***in vivo* testing**, respectively. There is no guarantee that the concentrations of the regulated DBPs track the concentrations of all DBPs of adverse health consequences. An implication is that current water quality management, based on standard values for individual by-products, is insufficient in responding to overall toxicity arising from all DBP species in drinking-water.

Contributions of organobromine compounds and bromate ion

Table 1

Regulations and perspectives on disinfection by-products

In general, the concentrations of brominated by-products formed by chlorination are lower than those of chlorinated by-products. However, brominated low molecular weight by-products such as brominated THMs and haloacetic acids (HAAs) are more toxic than chlorinated by-products (Plewa *et al.* 2002; Richardson *et al.* 2007). A complex mixture of by-products from humic acids formed by hypobromous acid has three-fold greater mutagenicity than that formed by hypochlorous acid (Echigo *et al.* 2004).

A previous study assessed the contribution of organobromine by-products to the induction of chromosomal aberrations in chlorinated water (Echigo *et al.* 2004). Total organic chlorine (TOCl) and total organic bromine (TOBr) in TOX were measured separately. This study found that the contribution of TOBr ranged from 28-52% in the actual tap water conditions of $[Br^-]/TOC = 0.05-0.1$ mg Br/mg C and $[HOCl]/TOC=1.0-1.5$ mg Cl_2 /mg C. In most chlorinated waters, the concentration of TOBr is far lower than that of TOCl; however, TOBr is more toxic. Thus, the contribution of TOBr can be unexpectedly large. In some parts of the world the concentrations of naturally-occurring bromide ions in source waters are often over 100 $\mu g/L$. In these cases, the contribution of TOBr to overall toxicity may exceed that of TOCl.

The contribution of bromate ions to the toxicity of ozonated and chlorinated water is very small or negligible, as shown in **Table 1**.

Figure 1 summarizes these findings on ozonated/chlorinated water. The areas of ellipses approximately show the strength of mutagenicity based on the results of chromosomal aberration test (Echigo *et al.* 2004). TOCl and TOBr are formed in chlorinated waters. Although the TOBr concentration is low, the contribution of TOBr to overall toxicity is significant. In waters that are both ozonated and chlorinated, oxidized by-products without halogen are formed, including bromate ions that contribute a very small proportion of the overall toxicity.

Figure 1

Figure 2 shows the induction of chromosomal aberrations by humic acid solutions containing bromide ion that had been chlorinated and ozonated/chlorinated (Echigo *et al.* 2004). When ozonation was followed by chlorination, the chromosomal aberration-inducing activity was less than that of water treated only with chlorine. Bromate ion up to 1.1 mg/L was formed by ozonation. Water containing bromated ions that has been treated only with ozone has a weak chromosomal aberration-inducing activity. Because ozonation changes the chemical structures of natural organic matter (NOM), different by-products will be formed and induction of chromosomal aberration is less in chlorinated water if it has been ozonated. Thus, ozonation can produce safer (chlorinated) drinking water even with forming bromate ion.

Figure 2

Some water supply utilities reduce bromide ion in raw water by chlorination to decrease the concentration of bromate ions that is formed by subsequent ozonation (Buffle *et al.*

Regulations and perspectives on disinfection by-products

2004). Chlorination before ozonation can result in formation of organobromine by-products (TOBr). However, the contribution of bromate ion to the toxicity of chlorinated water as a final product is negligible, and organobromine by-products have a far greater contribution as shown in **Figure 1**. Therefore, this procedure may increase overall toxicity of drinking-water and a careful safety evaluation should be performed before this is implemented.

Meeting water quality standards for individual DBPs (bromate ion in this case) may result in other potentially-significant problems being overlooked, leading to potentially inappropriate and potentially counter-productive treatment measures. Water quality standards for DBPs should be considered as a reference for water quality management. A relative evaluation on the toxicity of brominated organic by-products and bromate ion (**Figure 1**) and a result indicating the significance of ozonation (**Figure 2**) present examples of the necessity of measuring the overall toxicity of drinking-water.

Change of the toxicity of chlorinated water and its index

Since concentrations of THMs and HAAs in chlorinated drinking-water increase in water distribution systems (Tanaka *et al.* 1991; Sasaki & Ueda 1992; Summers *et al.* 1996; Arora *et al.* 1997), it is widely believed by water supply utilities that the toxicity of drinking water also increases.

On the other hand, it has been found that mutagenicity of chlorinated water and some chlorinated by-products is not stable. Meier *et al.* (1983) have examined the effect of pH on the stability of mutagenicity of chlorinated water. Mutagenicity of chlorinated humic acids decreases with increasing pH. Nazar & Rapson (1982) have shown that mutagenicity of the known organochlorine mutagens decreases by cleavage of organically bound chlorine. As cleavage of chlorine proceeds by hydroxide ion, mutagenicity decreases faster at higher pH. These findings have shown that the structure of some organochlorine compounds produced by chlorination can be changed by hydrolysis.

Itoh *et al.* (2006) investigated changes in the toxicity in chlorinated water after chlorine addition. **Figure 3** illustrates the results. The chromosomal aberration test and transformation test were carried out as indices to initiation activity and promotion activity, respectively. Firstly, it shows that initiation activity just after chlorination is stronger than promotion activity. This was found by a comparison between chlorinated water and various chemicals. Secondly, initiation activity is produced by chlorine, however, it is unstable and decreases sharply over time after chlorination even in the presence of residual chlorine. In contrast, promotion activity produced by chlorine increases slightly over time after chlorination.

Thus, toxicity that decreases or increases is present in chlorinated water. The increasing toxicity (promotion activity) is present in chlorinated water, however, initiation activity drastically decreases. Since the toxicity of water is measured by *in vitro* assays in this study,

Figure 3

Regulations and perspectives on disinfection by-products

it is not possible to get a conclusion on the change of toxicity on the human body. However, it should be noted that the overall toxicity associated with carcinogenic activity can be mainly attributed to initiation activity and presumably decreases over time after chlorination. This was also suggested by the non-two-stage transformation test that is an index of the sum of initiation and promotion activity.

It is well known that concentrations of typical by-products such as THMs and HAAs increase after chlorine injection based on studies on characteristics of DBPs formation by chlorination and factors affecting the DBPs yield (Rockhow *et al.* 1990; Zhuo *et al.* 2001; Liang & Singer 2003). Since many investigations have been carried out on the mutagenicity in chlorinated drinking water, some characteristics on the mutagenicity have been clarified. One of the representative characteristics is that the mutagenicity easily changes and decreases over time after disinfection depending upon pH and temperature of water (Rapson *et al.* 1980; Meier *et al.* 1983; Kinae *et al.* 1992; Ueda *et al.* 1996; Itoh *et al.* 2001). These findings suggest that the direction of change in the mutagenicity is inconsistent with those of THMs and HAAs. In addition to these previous view, **Figure 3** obtained by *in vitro* tests as indices of initiation activity and promotion activity shows that the toxicity of chlorinated water is not consistent with concentrations of THMs and HAAs. These by-products are widely measured, however, they would not be appropriate as indices to compare the toxicity of chlorinated drinking-water in distribution systems.

The stability of some DBPs after the production by chlorine has been examined and discussed (Glezer *et al.* 1999; Nikolaou *et al.* 2001; Lekkas & Nikolaou 2004; Xie 2004). MX, a strong mutagen and carcinogen (McDonald & Komulainen 2005), is also produced by chlorination, however, it has been found that it decreases over time after it is formed by chlorine (Meier *et al.* 1987; Kinae *et al.* 1992). This decrease could be attributed to hydrolysis and the reaction of MX with residual chlorine. This direction of change is in reverse to those of THMs and HAAs. In addition, the change in concentration of MX was quantitatively consistent with the change of the toxicity (Itoh *et al.* 2006). Consequently, MX is appropriate as an index for comparing the carcinogenicity of tap water near and far from a water purification plant.

This example suggests that we have to focus on the overall toxicity of chlorinated water and indicator by-products have to be selected in view of the purpose of water quality management.

Toxicity and characteristics of chlorine dioxide-treated water

The use of so-called ‘alternative’ (meaning non-chlorine) disinfectants can markedly reduce the levels of halogenated organic compounds, including THMs, in drinking-water (Fielding & Farrimond 1999; Singer *et al.* 1999; Barrett *et al.* 2000). DBPs formed by

Regulations and perspectives on disinfection by-products

chlorine dioxide including inorganic by-products such as chlorite and chlorate ions have also been examined (Chang *et al.* 2000a, b; Dabrowska *et al.* 2003; Veschetti *et al.* 2005). Chlorine dioxide is generally thought to be suitable for practical disinfection processes with reducing the levels of halogenated DBPs (Gates 1998). However, the use of alternative disinfectants have had unexpected consequences including the production of a different set of toxic DBPs (Sedlak & Von Gunten 2011). For this reason, we have to consider the overall level of toxicity of water that is formed by these disinfectants, in addition to typical halogenated DBPs.

From this point of view, *in vitro* short-term genotoxicity tests are useful, because they can evaluate the combined action of DBPs present in drinking water as complex mixtures. Actually, there have been some studies on the mutagenicity formation by chlorine dioxide and the comparison between waters treated with chlorine dioxide and chlorine (Donald *et al.* 1989; Anderson *et al.* 1990; Itoh *et al.* 2001; Guzzella *et al.* 2004; Onarca *et al.* 2004). As described in **Change of the toxicity of chlorinated water and its index**, the mutagenicity in chlorinated water changes over time after chlorination. A few studies show the change or persistence of DBPs formed by chlorine dioxide in distribution systems (Korn *et al.* 2002; Hoehn *et al.* 2003), however, no studies have been conducted on the change in the mutagenicity formed by chlorine dioxide over time after the water treatment. We have to consider that there are some differences in the mutagenicity level and the change rate of the mutagenicity over time after disinfection between chlorination and chlorine dioxide.

In one study the toxicity of chlorine dioxide-treated water and associated changes were examined and compared with that of chlorinated water (Itoh *et al.* 2007). The chromosomal aberration-inducing activity is produced by chlorination and chlorine dioxide; however, this activity is unstable and gradually decreases over time after the treatments. Moreover, this activity decreases even under conditions where residual chlorine and chlorine dioxide can be detected. Changes in the chromosomal aberration-inducing activity were estimated to compare the safety of drinking water treated with chlorine and chlorine dioxide in distribution systems. The time to reach the maximum chromosomal aberration-inducing activity observed in chlorinated water or chlorine dioxide-treated water was set at 24 hours or 10 hours, respectively, based on the data obtained. Decreasing rate constants for the chromosomal aberration-inducing activity were calculated as a function of the concentration of residual disinfectants. It has been found that the decreasing rate constant is smaller, as the residual disinfectant concentration is higher. Residual concentrations in distribution systems were set at 0.1 mg/L and 0.4 mg/L. **Figure 4** shows an estimated result based on typical drinking-water in Japan. The 1.0 on the vertical axis indicates the maximum chromosomal aberration-inducing activity in chlorinated water.

The levels of chloroform and TOX formed by chlorine dioxide were approximately

Figure 4

Regulations and perspectives on disinfection by-products

1 297 1% and 5-7%, respectively, of those formed by chlorination (Itoh *et al.* 2007). A major
2 298 advantage of chlorine dioxide over chlorine is that it produces significantly lower levels of
3 299 halogenated organic compounds. **Figure 4** shows, however, the chromosomal
4 300 aberration-inducing activity produced by chlorine dioxidation is stronger than would be
5 301 expected based on the quantity of the formed by-products. Therefore, it is important to note
6 302 that the use of chlorine dioxide instead of chlorine as an alternative disinfectant does not
7 303 dramatically reduce the mutagenicity of the treated water.

12 304 **Figure 4** shows that the activity in chlorine dioxide-treated water that induces
13 305 chromosomal aberrations decreases more slowly, indicating that the mutagenicity of chlorine
14 306 dioxide-treated water is more stable. The chromosomal aberration-inducing activity in
15 307 chlorine dioxide-treated water is weaker than that in chlorinated water just after treatments;
16 308 however, the difference in the two activities decreases over time after treatment. In particular,
17 309 when the residual disinfectants are 0.1 mg/L, the activity in chlorine dioxide-treated water
18 310 that induces chromosomal aberrations becomes equal to that in chlorinated water at
19 311 approximately four days. After that, the relationship is reversed. When the residual
20 312 disinfectants are 0.4 mg/L, the difference in the two activities does not rapidly decrease.

25 313 Assuming that the drinking-water is retained in distribution systems typically for less than
26 314 two days, **Figure 4** also suggests that the mutagenicity of chlorine dioxide-treated water
27 315 would be 70-80% of that of chlorinated water – a potential advantage of chlorine dioxide
28 316 treatment. In addition, although chlorine dioxide-treated water is less mutagenic than
29 317 chlorinated water, the difference is small when the drinking-water remains in the distribution
30 318 system for a long period of time.

36 319 Thus, while at face value chlorine dioxide treatment can ‘solve’ the THMs problem, it
37 320 should be noted that it is similar to chlorine in terms of the mutagenicity of drinking-water.

39 321 Chlorate ion and chlorite ion are formed as inorganic by-products by chlorine dioxide and
40 322 standard values have been set for these by-products that prevent its widespread use because
41 323 they are not easy to achieve. The finding presented here is an additional limitation in using
42 324 chlorine dioxide.

Contribution of DBPs to the estrogenic effects of drinking-water

47 326 The potential health risks of endocrine disrupting chemicals (EDCs) were of great public
48 327 interest in the mid to late 1990s. Many epidemiological studies have been conducted to
49 328 examine the relationship between adverse reproductive and developmental outcomes and
50 329 exposure to chlorinated drinking-water. Some reviews of these studies (Zavaleta *et al.* 1999;
51 330 International Programme on Chemical Safety 2000; Nieuwenhuijsen *et al.* 2000; U.S.
52 331 Environmental Protection Agency 2006) have suggested that adverse outcomes, such as
53 332 spontaneous abortion, stillbirth, low birth weight, neurotoxicity, and birth defects, can be
54 333

Regulations and perspectives on disinfection by-products

associated with THMs and chlorinated by-products. These associations were not reported in other studies and further research would be needed to confirm any association.

Hundreds of compounds have been listed as suspected EDCs (Endocrine Disruptor Screening and Testing Advisory Committee 1998), and most research on EDCs focuses on these individual micropollutants. In contrast, the relationship between the consumption of chlorinated water and reproductive and developmental toxicity has been explored in epidemiological studies as mentioned above. Therefore, chlorinated by-products formed from NOMs should be an interest in addition to typical EDCs.

We consider it is important to measure the estrogenic effects of raw water containing both micropollutants and NOMs, and of chlorinated by-products in addition to suspected EDCs. The Endocrine Disruptor Screening and Testing Advisory Committee (EDSTAC) (1998) established by the US EPA also recommended that a mixture of DBPs be evaluated for their potential to cause endocrine disruption.

Figure 5(a) illustrates the components of water that induce estrogenic effects and how they are changed by chlorination (Itoh *et al.* 2009). First, NOMs have a weak estrogenic effect that increases after chlorination. Itoh *et al.* (2000a) found that commercial humic acid exhibits the estrogenic effect, which increases upon chlorination. In addition, this study demonstrated that the estrogenic effect of concentrated Lake Biwa water using the XAD7HP resin increases up to 2.3 times upon chlorination. The reasons that chlorination increases the estrogenic effect could be 1) chlorine produces by-products such as organochlorine substances, which are estrogenic; 2) a low-molecular-weight fraction, which may bind to the estrogen receptor in a cell, increases due to the oxidation and hydrolysis caused by chlorination; and 3) chlorine releases estrogenic substances, which interact with humic substances in the aqueous environment. Itoh *et al.* (2000b) revealed that the main factor affecting the increase in the estrogenic effect is the effect of chlorination by-products. However, it has not been successful in identifying specific by-products contributing to the increase in the estrogenic effect.

In addition, coagulation and activated carbon treatment decreased the estrogenic effect of the source water, but chlorination increased the estrogenic effect of the source water and treated waters (Itoh *et al.* 2009). These results suggest that the estrogenic effect is formed due to the reaction of chlorine with organic matter that remains after water treatment. It should be emphasized that this phenomenon is very similar to the formation of THMs in the drinking water treatment process, that is, NOMs are major precursors for both the estrogenic effect and THMs.

On the other hand, the estrogenic effects of most micropollutants decrease after chlorination as shown in **Figure 5(a)**. The effects of chlorination of bisphenol A (BPA), 4-nonylphenol (4-NP), estrone (E_1), 17 β -estradiol (E_2), estriol (E_3), and 17 α -ethynylestradiol

Figure 5

Regulations and perspectives on disinfection by-products

(EE₂) on the estrogenic effect have been reported (Hu *et al.* 2002; Kuroto-Niwa *et al.* 2002; Lenz *et al.* 2003; Tabata *et al.* 2003; Deborde *et al.* 2004; García-Reyero *et al.* 2004; Lee *et al.* 2004; Nakamura *et al.* 2006; Kuruto-Niwa *et al.* 2007). In fact, some chlorinated derivatives or intermediates during chlorination of BPA and 4-NP show stronger estrogenic effect than parent compounds, however, the estrogenic effect of these compounds eventually decreases after the chlorination with chlorine dosage typically used in practice.

Different results have been reported about the effect of chlorination on the estrogenic effect of river water and treated wastewater. The estrogenic effect decreased by chlorination in some studies (Takigami *et al.* 1998; Akatsuka *et al.* 2000), however, it increased in other study (Yakou *et al.* 2000). **Figure 5 (a)** indicates that organic matters of which estrogenic effect increases or decreases after chlorination are present in raw water. The findings demonstrate that the overall estrogenic effects in chlorinated drinking-water are the sum of the increased and decreased activities of individual constituents after chlorination. The effect of chlorination depends on the quantity of the estrogenic effect that increases and decreases by chlorination.

In addition, the estrogenic effect originated from NOMs shown in **Figure 5(a)** following chlorination increased gradually over time, even in the absence of residual chlorine (Itoh *et al.* 2009). It is known that the concentration of THMs and HAAs increases while in the distribution system. The obtained result suggests that some part of the estrogenic effect in drinking water also increases over time after chlorination. The increase in estrogenic effect is faster at a higher pH than at a neutral pH, which is reasonable because the hydrolysis rate increases as the pH increases. Based on this finding, **Figure 5(b)** illustrates the components of the estrogenic effect originated from NOMs. It shows that the components, which form the “estrogenic effect formation potential” and “estrogenic effect intermediates”, can be defined. The estrogenic substances formed just after chlorination are part of the chlorinated by-products. The “estrogenic effect intermediates” change into estrogenic substances over time, explaining the increased estrogenic effect shown in **Figure 5(a)** continues to increase over time after chlorination.

This phenomenon is similar to the formation of THMs because NOMs are major precursors of both estrogenic effect and THMs. The “THM formation potential” and the “THM intermediates” in the formation process of THMs have definitions that are similar to those illustrated in **Figure 5(b)** (Xie 2004). To decrease the estrogenic effects of drinking-water, NOMs in addition to suspected EDCs should be removed before chlorination. Furthermore, it is important to assess the reproductive and developmental toxicity of mixtures of by-products that originated from NOMs.

ATTEMPTS TO ESTIMATE THE OVERALL TOXICITY OF

DISINFECTED WATER

In vitro mutagenicity testing

As discussed above, we have to pay much attention to numerous other DBPs in addition to typical ones formed by disinfection. It has been emphasized for many years that it is important to measure and evaluate the toxicity of complex DBP mixtures in chlorinated water. *In vitro* short-term bioassays such as the Ames test can evaluate the combined action of DBPs. Many studies have investigated the mutagenicity of organic extract in disinfected water, including chlorinated water (Loper *et al.* 1978; Donald *et al.* 1989). As mutagenicity tests, the Ames test had been mainly carried out until the 1980s, however, various kinds of *in vitro* bioassays such as assays using cultured mammalian cells have been performed after that.

Our review of studies that compared the mutagenicity of water treated with different disinfectants (Zoeteman *et al.* 1982; Backlund 1985; Meier & Bull 1985; Cognet *et al.* 1986; Kamei *et al.* 1989; Anderson *et al.* 1990; Sayato *et al.* 1991; DeMarini *et al.* 1995; Monarca *et al.* 1998; Guzzella *et al.* 2004; Maffei *et al.* 2005) found that a study by Meier & Bull (1985) yielded typical results. This study showed that the mutagenicity of chlorinated water was the strongest and that chloramine-treated water was also mutagenic. The mutagenicity of chlorine dioxide-treated water was minimal, and ozonated water had no detected mutagenicity. DeMarini *et al.* (1995) showed that different types of disinfected water had mutagenicity in the following order: chlorination > ozonation plus chlorination > chloramination > ozonation plus chloramination > ozonation > raw water. There are additional findings on ozonation such as; ozone has the effect that reduces the mutagenicity of raw water (Zoeteman *et al.* 1982); the mutagenicity of ozonated water is detected in some cases (Cognet *et al.* 1986) and not in others (Meier & Bull 1985; Anderson *et al.* 1990). In addition, these results may vary with raw water quality and a sample preparation procedure etc. For example, Sayato *et al.* (1991) showed that chlorination reduces mutagenicity because the mutagenicity of raw water is strong.

Performing *in vitro* mutagenicity testings is not quantifications of individual chemicals by chemical analysis, and they can provide one of the indicators of the overall toxicity of water. As a matter of fact, epidemiological studies have reported associations between the mutagenicity of chlorinated drinking-water and increased risk of cancers of bladder, rectum, kidney, pancreas, and lymphatic system (Koivusalo *et al.* 1995; Koivusalo *et al.* 1997; Koivusalo *et al.* 1998). The results of *in vitro* mutagenicity testings can be employed for reducing risk of drinking water, and can contribute to develop a better water treatment process. On the other hand, these tests have the limitation that toxicity to the human body cannot be assessed and a health-based value cannot be derived by extrapolating the results

Regulations and perspectives on disinfection by-products

for humans.

***In vivo* testing**

It is essential to estimate the overall toxicity of disinfected water with *in vivo* assays so that the toxicity of TOX i.e., complex mixtures of chlorinated water, can be estimated. However, only a few carcinogenicity studies using experimental animals have been conducted.

Bull *et al.* (1982) showed an increased number of tumors when concentrates of US drinking-water were applied to mouse skin as tumor initiators in initiation/promotion studies. The same study also showed that water disinfected by chlorine, ozone, and chloramine resulted in a greater number of papillomas compared to nondisinfected water. Van Duuren *et al.* (1986) administered a chlorinated humic acid solution (1 g TOC/L) as drinking-water to mice for two years. There were no increases in tumors. Similarly no adverse effects relevant to carcinogenicity have been detected in other studies (Kool *et al.* 1985; Miller *et al.* 1986; Condie *et al.* 1994). Condie *et al.* (1985) carried out a sub-chronic toxicity test administering chlorinated humic acid solution in drinking water for 90 days. NOAEL (no-observed adverse effect level) was derived as 0.5 g-TOC/L. Daniel *et al.* (1991) conducted a sub-chronic toxicity test in male and female rats. A provisional NOAEL of untreated humic acid solution, ozonated water and ozonated/chlorinated water was set to be 1.0 g-TOC/L.

In summary, no studies have shown evidence of the carcinogenic effects of complex DBP mixtures via drinking-water consumed by rodents. There have been many epidemiological studies of associations between consumption of chlorinated drinking-water and increased risk of various cancers (International Agency for Research on Cancer 2004; U.S. Environmental Protection Agency 2006). The US EPA has concluded that the available data indicates a potential association between consumption of drinking-water and bladder cancer, and it also suggests a potential association between consumption of drinking-water and rectal and colon cancers. Although an epidemiological study is useful as a means to observe adverse effects on human health, there is no attempt to date to derive health-based values of DBPs based on epidemiological evidence. *In vivo* assays using experimental animals should be given a higher priority to derive a health-based value of a DBP mixture.

Toxicity estimation project initiated by the US EPA

Available evidence suggests that it will be essential to perform *in vivo* toxicity tests on disinfected water to obtain results that can be used to derive water quality standards for TOX ($\mu\text{g Cl/L}$). The US EPA has initiated the Integrated Disinfection Byproducts Mixture Research Project for this purpose (Simmons *et al.* 2002; 2004).

In this project, the following *in vivo* toxicology tests will be performed: reproductive and

Regulations and perspectives on disinfection by-products

developmental toxicity, mutagenicity, carcinogenicity, immunogenicity, hepatic/renal toxicity, neurotoxicity, developmental neurotoxicity, and kinetics/metabolism. *In vitro* bioassays on similar types of toxicity have also been designed to be performed. It is very valuable that, in addition to *in vitro* bioassays, *in vivo* toxicity studies that are associated not only with carcinogenicity but also with other several types of toxicity have been planned.

This project confronts challenging technical issues such as the development of a concentration procedure using a reverse osmosis membrane (Speth *et al.* 2008), preparation of water concentrates that are drinkable by laboratory animals (Narotsky *et al.* 2008), and ensuring the chemical stability of water concentrates (McDonald *et al.* 2010). Since multi-disciplinarity is needed to tackle these technical issues, specialists from different fields have designed and initiated this huge project.

The reproductive and developmental endpoints are being given first priority in this project. The results obtained to date showed that 130-fold concentrates of both chlorinated and ozonated/postchlorinated water appeared to exert no adverse developmental effects (Narotsky *et al.* 2008). Cancer endpoints, however, were assigned a lower priority because of the difficulty in obtaining enough water concentrate for a two-year cancer bioassay. In addition, water is disinfected either by chlorination or by ozonation/postchlorination, and there is no plan to research adverse effects of water that has been treated with chlorine dioxide or chloramines (Simmons *et al.* 2008). Future research progress is highly encouraged.

Since obtaining useful information for actual regulation depends on the progress and success of *in vivo* bioassays, they should be given a higher international priority.

CONCLUSIONS AND RECOMMENDATIONS

The regulation of DBPs has played a great role in producing safe drinking-water; however, there are numerous limitations with the current system. Only a few of the 600-700 chlorinated by-products are regulated, accounting for only a small portion of the overall toxicity represented by DBPs.

Water suppliers typically focus their water quality management efforts to comply with defined maximum concentration standards for individual regulated parameters. As a result, toxicity from causes other than regulated by-products is overlooked, leading to potentially inappropriate and potentially counter-productive treatment measures. The contribution of bromate ion to overall water toxicity (**Figure 1**) and the toxicity and changes in chlorine dioxide-treated water (**Figure 4**) are good examples. Standard values are never sufficient as golden rules as far as DBPs are concerned. Instead, they should serve as important points of reference for water quality management.

Regulations and perspectives on disinfection by-products

We recommend a paradigm shift towards preventive and holistic DBP management based on a comprehensive health-based risk assessment that takes into account the overall toxicity. This approach is recommended in the WHO Guidelines for Drinking-water Quality as "Water Safety Plans" (WSPs). WSPs require assessment of risks from catchment to consumer, and implementation of control measures that are validated to effectively mitigate risks. Moreover, the WSP approach puts more emphasis on monitoring of control measures rather than on monitoring at end-of-pipe against an ever-growing list standards. The implication for DBP management is to focus efforts on the implementation and monitoring of preventive control measures such as removal of DBP precursor compounds, the consideration of the costs and benefits of using alternative or non-chemical disinfection processes, and if appropriate, to establish and validate removal of DBPs prior to distribution. Care must be taken to not compromise disinfection efficacy in efforts to reduce DBP toxicity, and this should also be demonstrated in the WSP risk management plan.

Other than a progressive shift to promotion of WSPs, there may be a limited number of immediately implementable policy or regulatory actions. One step would be to keep standard values that have been derived with sufficiently large safety (uncertainty) factors. For example, first, an alternative approach such as the benchmark dose method has been introduced to derive tolerable daily intakes (TDIs). This method may give a new health-based value that differs from a previous value, even when the same toxicity data are analyzed. Second, it has been emphasized that a standard value should be set using an appropriate allocation of the TDI to drinking-water. An actual measurement of the proportion of intake from drinking-water may give a new allocation of intake instead of the default value, ultimately resulting in a new health-based value. Even in these cases, however, any changes in the present standard values should be considered carefully and the overall toxicity of water should be considered.

International organizations and national standard value setting committees should collect information on the overall toxicity of disinfected water. Obtaining useful information for actual regulation depends on the progress and success of *in vivo* bioassays that can be used to derive health-based values. Therefore, *in vivo* assays with experimental animals should be given a higher international priority.

ACKNOWLEDGEMENTS

We would like to express our appreciation to Associate Professor Shinya Echigo of the Department of Environmental Engineering of Kyoto University for helping us obtain data and information on brominated-DBPs.

REFERENCES

Akatsuka, Y., Kamata, M., Takeda, M., Kamei, T., Magara, Y., Nishikawa, J. & Nishihara, T.

Regulations and perspectives on disinfection by-products

- 2000 The research for the behavior of the estrogenic activity in water treatment processes. *Proc. 34th Annual Conference of Japan Society of Wat. Environ.* 204 (in Japanese).
- Anderson, W. B., Huck, P. M., Dagnault, S. A., Irvine, G. A., Rector, D. W., Savege, E., von Borstel, R. C. & Williams, D. T. 1990 Comparison of drinking-water disinfectants using mutagenicity testing. In: Jolly, R. L., Condie, L. W., Johnson, J. D., Katz, S., Minear, R. A., Mattice, J. S. & Jacobs, V. A. (eds). *Water Chlorination: Chemistry, Environmental Impact and Health Effects*. Chelsea, MI: Lewis Publishers **6**, 201-225.
- Arora, H., LeChevallier, M. W. & Dixon, K. 1997 DBP occurrence survey. *J. Am. Water Works Assoc.* **89**(6), 60-68.
- Backlund, P. 1985 Mutagenic activity in humic water and alum flocculated humic water treated with alternative disinfectants. *Sci. Total Environ.* **47**, 257.
- Barrett, S. E., Krasner, S. W. & Amy, G. L. (eds.) 2000 *Natural Organic Matter and Disinfection By-products, Characterization and Control in Drinking Water*. Am. Chemical Society, Washington, D. C., USA.
- Buffle, M. O., Galli, S. & von Gunten, U. 2004 Enhanced bromate control during ozonation: The chlorine-ammonia process. *Environ. Sci. Technol.* **38**(19), 5187-5195.
- Bull, R. J., Robinson, M., Meier, J. R. & Stober, J. 1982 Use of biological assay systems to assess the relative carcinogenic hazards of disinfection by-products. *Environ. Health Perspect.* **46**, 215-227.
- Chang, C.Y., Hsieh, Y.H., Hsu, S.S., Hu, P.Y. & Wang, K.H. 2000a The formation of disinfection by-products in water treated with chlorine dioxide. *J. of Hazardous Materials* **B79**, 89-102.
- Chang, C.Y., Hsieh, Y.H., Shih, I.C., Hsu, S.S. & Wang, K.H. 2000b The formation and control of disinfection by-products using chlorine dioxide. *Chemosphere* **41**, 1181-1186.
- Cognet, L., Courtois, Y. & Mallevialle, J. 1986 Mutagenic activity of disinfection by-products. *Environ. Health Perspect.* **69**, 165.
- Condie, L., Laurie, R., & Bercz, J. 1985 Subchronic toxicology of humic acid following chlorination in the rat. *J. Toxicol. Environ. Health* **15**, 305-314.
- Condie, L. W., Lauer, W.C., Wolfe, G. W., Czech, E. T. & Burns, J. M. 1994 Denver potable water reuse demonstration project: comprehensive chronic rat study. *Food Chem. Toxicol.* **32**, 1021-1030.
- Council on Public Welfare Science 2003 *Revision of Drinking Water Quality Standards* (in Japanese).
- Dabrowska, A., Swietlik, J. & Nawrocki, J. 2003 Formation of aldehydes by ClO₂ disinfection. *Wat. Res.* **37**, 1161-1169.
- Daniel, F. B., Robinson, M., Rlnghand, H. P., Stober, J. A., Page, N. P. & Olson, G. R. 1991 Subchronic toxicity study of ozonated and ozonated/chlorinated humic acids in Sprague-Dawley rats: A model system for drinking-water disinfection. *Environ. Sci. Technol.* **25**(1), 93-98.
- Deborde, M., Rabouan, S., Gallard, H. & Legube, B. 2004 Aqueous chlorination kinetics of some endocrine disruptors. *Environ. Sci. Technol.* **38**(21), 5577-5583.
- DeMarini, D. M., Abu-Shakra, A., Felton, C. F., Patterson, K. S. & Shelton, M. L. 1995 Mutation spectra in *Salmonella* of chlorinated, chloraminated or ozonated drinking-water extracts: Comparison to MX. *Environ. Mol. Mutagen.* **26**, 270-285.
- Donald, K. D., William, B. A., Susan, A. D., David, T. W. & Peter, M. H. 1989 Evaluating treatment processes with the Ames mutagenicity assay. *J. Am. Water Works Assoc.* **89**(9), 87-102.
- Echigo, S., Itoh, S., Natsui, T., Araki, T. & Ando, R. 2004 Contribution of brominated organic disinfection by-products to the mutagenicity of drinking-water. *Water Sci. Technol.* **50**(5), 321-328.
- Endocrine Disruptor Screening and Testing Advisory Committee (EDSTAC) 1998 *Final Report*.
- European Union 1998 Council Directive 98/83/EC on the quality of water intended for human consumption, *Official Journal of the European Communities*, L330/32-54.
- Fielding, M. & Farrimond, M. (eds.) 1999 *Disinfection By-products in Drinking Water. Current Issues*. Royal Society of Chemistry, UK.
- García-Reyero, N., Requena, V., Petrovic, M., Fischer, B., Hansen, P. D., Díaz, A., Ventura, F., Barceló, D. & Piña, B. 2004 Estrogenic potential of halogenated derivatives of nonylphenol ethoxylates and carboxylates. *Environ. Toxicol. Chem.* **23**(3), 705-711.
- Gates, D. 1998 *The Chlorine Dioxide Handbook*. 186p., Am. Wat. Wks. Assoc., Denver,

Regulations and perspectives on disinfection by-products

- 1 617 USA.
- 2 618 Glezer, V., Harri, B., Tal, N., Iosefzon, B. & Lev, O. 1999 Hydrolysis of haloacetonitriles:
- 3 619 Linear free energy relationship, kinetics and products. *Wat. Res.* **33**(8), 1938-1948.
- 4 620 Guzzella, L., Monarca, S., Zani, C., Feretti, D., Zerbini, I., Buschini, A., Poli, P., Rossi, C.,
- 5 621 & Richardson, S. D. 2004 *In vitro* potential genotoxic effects of surface drinking-water
- 6 622 treated with chlorine and alternative disinfectants. *Mutat. Res.- Genetic Toxicol. Environ.*
- 7 623 *Mutagen* **564**, 179-193.
- 8 624 Health Canada 2007 *Guidelines for Canadian Drinking Water Quality*.
- 9 625 Hoehn, R.C., Ellenberger, C.S., Gallagher, D. L., Wiseman, E. V., Benninger, R. W. &
- 10 626 Rosenblatt, A. 2003 ClO₂ and by-product persistence in a drinking water system. *J. Am.*
- 11 627 *Wat. Wks. Assoc.* **95**(4), 141-150.
- 12 628 Hu, J., Aizawa, T. & Ookubo, S. 2002 Products of aqueous chlorination of bisphenol A and
- 13 629 their estrogenic activity. *Environ. Sci. Technol.* **36**(9), 1980-1987.
- 14 630 International Agency for Research on Cancer (IARC) 2004 *IARC Monographs on the*
- 15 631 *Evaluation of Carcinogen Risks to Humans Volume 84 Some Drinking Water*
- 16 632 *Disinfectants and Contaminants, including Arsenic*. Lyon, France: IARC.
- 17 633 International Programme on Chemical Safety 2000 *Environmental Health Criteria 216,*
- 18 634 *Disinfectants and Disinfection By-products*. Geneva, Switzerland: World Health
- 19 635 Organization.
- 20 636 Itoh, S., Ueda, H., Nagasaka, T. & Sumitomo, H. 2000a Evaluating variation of estrogenic
- 21 637 effect by drinking water chlorination with the MVLN assay. *Wat. Sci. Technol.* **42**(7-8),
- 22 638 61-69.
- 23 639 Itoh, S., Nagasaka, T., Nakanishi, G., Nonaka, A. & Dodo, O., 2000b Characteristics of
- 24 640 estrogenic effect of drinking water and its control,” *Environ. Eng. Res.* **37**, 333-344 (in
- 25 641 Japanese).
- 26 642 Itoh, S., Ikeda, D., Toba, Y. & Sumitomo, H. 2001 Changes of activity inducing
- 27 643 chromosomal aberrations and transformations of chlorinated humic acid. *Wat. Res.* **35**(11),
- 28 644 2621-2628.
- 29 645 Itoh, S., Nakano, A. & Araki, T. 2006 Reevaluation of the toxicity of chlorinated water and
- 30 646 the usefulness of MX as an index. *J. Water and Health* **4**(4), 523-531.
- 31 647 Itoh, S., Murakami, H., Fukuhara, M. & Nakano, A. 2007 Limitations of chlorine dioxide as
- 32 648 an alternative disinfectant in comparison with chlorine from the viewpoint of
- 33 649 mutagenicity, *J. Water Supply: Res. and Technol. AQUA* **56**(2), 95-104.
- 34 650 Itoh, S. & Echigo, S. 2008 *Disinfection By-products in Water*. Tokyo, Japan, GIHOUDOU
- 35 651 SHUPPAN Co., Ltd. (in Japanese).
- 36 652 Itoh, S., Yoshimura, Y. & Okada, T. 2009 Components of estrogenic effect in chlorinated
- 37 653 drinking-water. *Advances in Asian Environ. Eng.* **8**(1), 31-38.
- 38 654 Kamei, T., Tambo, N. & Kaneko, A. 1989 Mutagenicity of by-products formed in humic
- 39 655 substances by chlorine, chloramines and chlorine dioxide. *J. Japan Water Works Associ.*
- 40 656 **58**(2), 21-29 (in Japanese).
- 41 657 Karanfil, T., Krasner, S. W., Westerhoff, P. & Xie, Y. 2008 Recent advances in disinfection
- 42 658 by-products formation, occurrence, control, health effects, and regulations. In: Karanfil, T.,
- 43 659 Krasner, S. W., Westerhoff, P., Xie, Y. (eds). *Disinfection By-products in Drinking Water*.
- 44 660 ACS Symposium Series 995, Washington, DC, American Chemical Society, 2-19.
- 45 661 Kinae, N., Sugiyama, C., Nasuda, M. Y., Goto, K., Tokumoto, K., Furugori, M. & Shimoi, K.
- 46 662 1992 Seasonal variation and stability of chlorinated organic mutagens in drinking water.
- 47 663 *Wat. Sci. Technol.* **25**(11), 333-340.
- 48 664 Kinae, N., Sugiyama, C. & Shimoi, K. 2000 Formation of direct mutagen MX in water
- 49 665 samples and induction of toxic effects. *Environ. Mutagen Res.* **22**, 141-148 (in Japanese).
- 50 666 Koivusalo M., Vartiainen, T., Hakulinen, T., Pukkala, E. & Jaakkola, J. 1995 Drinking water
- 51 667 mutagenicity and leukemia, lymphomas, and cancers of the liver, pancreas, and soft tissue.
- 52 668 *Archives Environ. Health* **50**(4), 269-276.
- 53 669 Koivusalo M., Pukkala, E., Vartiainen, T., Jaakkola, J. & Hakulinen,
- 54 670 T. 1997 Drinking water chlorination cancer – a historical cohort study in Finland. *Cancer*
- 55 671 *Causes Control* **8**, 192-200.
- 56 672 Koivusalo M., Hakulinen, T., Vartiainen, T., Pukkala, E., Jaakkola, J. & Tuomisto, J. 1998
- 57 673 Drinking water mutagenicity and urinary tract cancers: A population-based case-control
- 58 674 study in Finland. *Am. J. Epidemiol.* **148**(7), 704-712.
- 59 675 Kool, H. J., Kuper, F., van Haeringen, H. & Koeman, J. H. 1985 A carcinogenicity study
- 60 676 with mutagenic organic concentrates of drinking-water in the Netherlands. *Food Chem.*

Regulations and perspectives on disinfection by-products

- Toxicol.* **23**, 79–85.
- Korn, C., Andrees, R. C. & Escobar, M. D. 2002 Development of chlorine dioxide-related by-product models for drinking water treatment. *Wat. Res.* **36**(1), 330-342.
- Krasner, S. W., McGuire, M. J., Jacangelo, J. G., Patania, N. L., Reagan, K. M. & Aieta, E. W. 1989 The occurrence of disinfection by-products in U. S. drinking-water. *J. Am. Water Works Assoc.* **81**(8), 41-53.
- Kronberg, L., Holmbom, B., Reunanen, M. & Tikkanen, L. 1988 Identification and quantification of the Ames mutagenic compound 3-chloro-4-(dichloromethyl)-5-hydroxy-2(5H)-furanone and of its geometric isomer (E)-2-chloro-3-(dichloromethyl)-4-oxobutenoic acid in chlorine-treated humic water and drinking-water extracts. *Environ. Sci. Technol.* **22**, 1097–1103.
- Kuroto-Niwa, R., Terao, Y. & Nozawa, R. 2002 Identification of estrogenic activity of chlorinated 11 bisphenol A using a GFP expression system. *Environ. Toxicol. and Pharmacol.* **12**, 27-35.
- Kuruto-Niwa, R., Ito, T., Goto, H., Nakamura, H., Nozawa, R. & Terao, Y. 2007 Estrogenic activity of the chlorinated derivatives of estrogens and flavonoids using a GFP expression system. *Environ. Toxicol. Pharmacol.* **23**(1), 121-128.
- Lee, B. C., Kamata, M., Akatsuka, Y., Takeda, M., Ohno, K., Kamei, T. & Magara, Y. 2004 Effects of chlorine on the decrease of estrogenic chemicals. *Water Res.* **38**(3), 733-739.
- Lekkas, T. D. & Nikolaou, A. D. 2004 Degradation of disinfection byproducts in drinking water. *Environ. Eng. Sci.* **21**(4), 493-506.
- Lenz, K., Beck, V. & Fuerhacker, M. 2003 Behavior of bisphenol A (BPA), 4-nonylphenol (4-NP) and 4-nonylphenol ethoxylates (4-NP1EO, 4-NP2EO) in oxidative water treatment processes. *Proceedings of The 4th IWA Specialized Conference on Assessment and Control of Hazardous Substances in Water –ECOHazard 2003–* Aachen, Germany, 14-17 Sep. 2003, 5/1-5/7.
- Liang, L. & Singer, C. 2003 Factors influencing the formation and relative distribution of haloacetic acids and trihalomethanes in drinking water. *Environ. Sci.* **37**, 2920-2928.
- Loper, J. C., Lang, D. R., Schoeny, R. S., Richmond, B. B., Gallagher, P. M. & Smith, C. C. 1978 Residue organic mixtures from drinking water show in vitro mutagenic and transforming activity. *J. Toxicol. Environ. Health* **4**, 919-938.
- Maffei, F., Buschini, A., Rossi, C., Poli, P., Forti, G. C. & Hrelia, P. 2005 Use of the comet test and micronucleus assay on human white blood cells for *in vitro* assessment of genotoxicity induced by different drinking-water disinfection protocols. *Environ. Mol. Mutagen.* **46**, 116-25.
- McDonald, A., Killough, P., Puckett, E., Best, D. S., Simmons, J. E., Pressman, J. G. & Narotsky, M. G. 2010 A novel water delivery system for administering volatile chemicals while minimizing chemical waste in rodent toxicity studies. *Laboratory Animals* **44**(1), 66-68.
- McDonald, T. A. & Komulainen, H. 2005 Carcinogenicity of the chlorination disinfection by-product MX. *J. Environ. Sci. Health, Part C* **23**, 163-214.
- Meier, J. R., Lingg, R. D. & Bull, R. J. 1983 Formation of mutagens following chlorination of humic acid: a model for mutagen formation during water treatment. *Mutat. Res.* **118**, 15–41.
- Meier, J. R., Ringhand, H. P., Coleman, W. E., Munch, J. W., Streicher, R. P., Kaylor, W. H. & Schenck, K. M. 1985 Identification of mutagenic compounds formed during chlorination of humic acid. *Mutat. Res.* **157**, 111-122.
- Meier, J. R. & Bull, R. J. 1985 Mutagenic properties of drinking-water disinfectants and by-products. In: Jolly, R. L., Bull, R. J., Davis, W. P., Katz, S., Robert, M. H., Jacobs, V. A. (eds). *Water Chlorination : Chemistry, Environmental Impact and Health Effects*. Chelsea, MI, Lewis Publishers, **5**, 207-220.
- Meier, J. R., Knohl, R. B., Coleman, W. E., Ringhand, H. P., Munch, J. W., Kaylor, W. H., Streicher, R. P. & Kopfler, F. C. 1987 Studies on the potent bacterial mutagen, 3-chloro-4-(dichloromethyl)-5-hydroxy-2(5H)-furanone: aqueous stability, XAD recovery and analytical determination in drinking water and in chlorinated humic acid solutions. *Mutat. Res.* **189**, 363-373.
- Miller, R. G., Kopfler, F. C., Condie, L. W., Pereira, M. A., Meier, J. R., Ringhand, H. P., Robinson, M. & Casto, B. C. 1986 Results of toxicological testing of Jefferson Parish pilot plant samples. *Environ. Health Perspect.* **69**, 129-139.
- Monarca, S., Zanardini, A., Feretti, D., Dalmiglio, A., Falistocco, E., Manica, P. & Nardi, G.

Regulations and perspectives on disinfection by-products

- 1998 Mutagenicity of extracts of lake drinking-water treated with different disinfectants in bacterial and plant tests. *Wat. Res.* **32**(9), 2689-2695.
- Nakamura, H., Shiozawa, T., Terao, Y., Shiraishi, F. & Fukazawa, H. 2006 By-products produced by the reaction of estrogens with hypochlorous acid and their estrogen activities. *J. Health Sci.* **52**(2), 124-131.
- Narotsky, M. G., Best, D. S., Rogers, E. H., McDonald, A., Sey, Y. M. & Simmons, J. E. 2008 Integrated disinfection by-products mixtures research: Assessment of developmental toxicity in Sprague-Dawley rats exposed to concentrates of water disinfected by chlorination and ozonation/postchlorination. *J. Toxicol. Environ. Health, Part A* **71**(17), 1216 – 1221.
- Nazar, M. A. & Rapson, W. H. 1982 pH stability of some mutagens produced by aqueous chlorination of organic compounds. *Environ. Mutagen.* **4**, 435-444.
- Nieuwenhuijsen, M. J., Toledano, M. B., Eaton, N. E., Fawell, J. & Elliott, P. 2000 Chlorination disinfection byproducts in water and their association with adverse reproductive outcomes: A review. *Occup. Environ. Med.* **57**, 73-85.
- Nikolaou, A. D., Lekkas, T. D., Kostopoulou, M. N. & Golfinopoulos, S. K. 2001 Investigation of the behaviour of haloketons in water samples. *Chemosphere* **44**(5), 907-912.
- Onarca, S.M., Zani, C., Richardson, S.D., Thruston, A.D., Moretti, M., Feretti, D. & Villarini, M. 2004 A new approach to evaluating the toxicity and genotoxicity of disinfected drinking water. *Wat. Res.* **38**, 3809-3819.
- Plewa, M. J., Kargalioglu, Y., Vakerk, D., Minear, R. A. & Wagner, E. D. 2002 Mammalian cell cytotoxicity and genotoxicity analysis of drinking-water disinfection by-products. *Environ. Mol. Mutagen.* **40**, 134-142.
- Rapson, W. H., Nazar, M. A. & Butsky, V. 1980 Mutagenicity produced by aqueous chlorination of organic compounds. *Bull. Environ. Contam. Toxicol.* **24**, 590-596.
- Richardson, S. D. 1998 Identification of drinking-water disinfection byproducts. In: Mayers, R. A. (ed). *Encyclopedia of environmental analysis and remediation*. New York, John Wiley and sons, 1398-1421.
- Richardson, S. D., Plewa, W. J., Wagner, E. D., Schoeny, R. & DeMarini, D. M. 2007 Occurrence, genotoxicity, and carcinogenicity of regulated and emerging disinfection by-products in drinking-water: A review and roadmap for research. *Mutat. Res./Reviews in Mutat. Res.* **636**(1-3), 178-242.
- Rockhow, D.A., Singer, P.C. & Malcolm, R.L. 1990 Chlorination of humic materials: byproduct formation and chemical interpretations. *Environ. Sci.* **24**, 1655-1664.
- Sasaki, T. & Ueda, S. 1992 Control technology for disinfection by-products including alternate disinfectants in Japan. *3rd US-Japan Governmental Conference on Drinking Water Quality Management, Cincinnati, Ohio & Los Angeles, California*, September 20-25.
- Sayato, Y., Nakamuro, K., Ueno, J., Hasegawa, T. & Goto, R. 1991 Behavior of mutagenic activity in water treatment process. *J. Japan Water Works Associ.* **60**(6), 2-20 (in Japanese).
- Sedlak, D. L., & Von Gunten, U. 2011 The chlorine dilemma. *Science* **331**, 42-43.
- Simmons, J. E., Richardson, S. D., Speth, T. F., Miltner, R. J., Rice, G., Schenck, K. D., Hunter III, E. S. & Teuschler, L. K. 2002 Development of a research strategy for integrated technology-based toxicological and chemical evaluation of complex mixtures of drinking-water disinfection byproducts. *Environ. Health Perspect.* **110**, Supplement 6, 1013-1024.
- Simmons, J. E., Teuschler, L. K., Gennings, C., Speth, T. F., Richardson, S. D., Miltner, R. J., Narotsky, M. G., Schenck, K. D., Hunter III, E. S., Hertzberg, R. C. & Rice, G. 2004 Component-based and whole-mixture techniques for addressing the toxicity of drinking-water disinfection by-product mixtures. *J. Toxicol. Environ. Health, Part A* **67**, 741-754.
- Simmons, J. E., Richardson, S. D., Teuschler, L. K., Miltner, R. J., Speth, T. F., Schenck, K. M., Hunter III, E. S. & Rice, G. 2008 Research issues underlying the four-lab study: Integrated disinfection by-products mixtures research. *J. Toxicol. Environ. Health, Part A* **71**(17), 1125 – 1132.
- Singer, P. C. (ed) 1999 *Formation and Control of Disinfection By-products in Drinking Water*. Am. Wat. Wks. Assoc., Denver, USA.
- Speth, T. F., Miltner, R. J., Richardson, S. D. & Simmons, J. E. 2008 Integrated disinfection

Regulations and perspectives on disinfection by-products

- by-products mixtures research: Concentration by reverse osmosis membrane techniques of disinfection by-products from water disinfected by chlorination and ozonation/postchlorination. *J. Toxicol. Environ. Health, Part A* **71**(17), 1149-1164.
- Stevens, A. A., Moore, L. A., Slocum, C. J., Smith, B. L., Seeger, D. R. & Ireland, J. C. 1990 By-products of chlorination at ten operating utilities, In: Jolly, R. L., Condie, L. W., Johnson, J. D., Katz, S., Minear, R. A., Mattice, J. S. & Jacobs, V. A. (eds). *Water Chlorination: Chemistry, Environmental Impact and Health Effects*. Chelsea, MI, Lewis Publishers, **6**, 579-604.
- Summers, R. S., Hooper, S. M., Shukairy, H. M., Solarik, G. & Owen, D. 1996 Assessing DBP yield: uniform formation conditions. *J. Am. Water Works Assoc.* **88**(6), 80-93.
- Tabata, A., Watanabe, N., Yamamoto, I., Ohnishi, Y., Itoh, M., Kamei, T., Magara, Y. & Terao, Y. 2003 The effect of bisphenol A and chlorinated derivatives of bisphenol A on the level of serum vitellogenin in Japanese Medaka (*Oryzias Latipes*). *Proceedings of The 4th IWA Specialized Conference on Assessment and Control of Hazardous Substances in Water –ECOHazard 2003–*, Aachen, Germany, Sep. 2003.
- Takigami, H., Matsuda, T. & Matsui, S. 1998 Detection of estrogen-like activity in sewage treatment process waters. *Environ. Sanitary Eng. Res.* **12**(3), 214-219.
- Tanaka, K., Shikada, Y., Matsuda, A. & Takahashi, Y. 1991 Occurrence of organic halogens and mutagenicity in drinking water in Niigata district of Japan, In *Proc. of the First IAWPRC International Symposium on Hazard Assessment and Control of Environmental Contaminants in Water, Otsu, Japan*, November 25-28, 468-475.
- Ueda, H. 1996 Changes of disinfection by-products in drinking water by the adjustment of pH. *J. Wat. Waste* **38**(12), 20-26 (in Japanese).
- U.S. Environmental Protection Agency 2006 National Primary Drinking Water Regulations: Stage 2 Disinfectants and Disinfection Byproducts Rule; Final Rule, *Federal Register* **71**(2), 388-493.
- Van Duuren, B. L., Melchionne, S., Seidman, I. & Periera, M. A. 1986 Chronic bioassays of chlorinated humic acids in B6C3F1 mice. *Environ. Health Perspect.* **69**, 109-117.
- Veschetti, E., Cittadini, B., Maresca, D., Citti, G. & Ottaviani, M. 2005 Inorganic by-products in waters disinfected with chlorine dioxide. *Microchemical J.* **79**, 165-170.
- World Health Organization 2006 *Guidelines for drinking-water quality incorporating first addendum*. Recommendations – 3rd ed. Geneva, Switzerland, World Health Organization, **1**.
- Xie, Y. F. 2004 *Disinfection Byproducts in Drinking Water: Formation, Analysis, and Control*. 161p., Lewis Publishers, Boca Raton, Florida, USA.
- Yakou, Y., Takahashi, A., Higashitani, T. & Tanaka, H. 2000 Fate of estrogen-like activity in wastewater treatment plants by recombinant yeast. *Proc. 34th Annual Conference of Japan Society of Wat. Environ.* 419 (in Japanese).
- Zavaleta, J. O., Hauchman, F. S. & Cox, M.W. 1999 Epidemiology and toxicology of disinfection by-products. In: Singer, P. C. (ed). *Formation and Control of Disinfection By-products in Drinking-water*. Denver, CO, Am. Water Works Assoc., 95-117.
- Zhuo, C., Chengyong, Y., Junhe, L., Huixian, Z. & Jinqi, Z. 2001 Factors on the formation on disinfection by-products MX, DCA and TCA by chlorination of fulvic acid from lake sediments. *Chemosphere* **45**, 379-385.
- Zoeteman, B. C. J., Hrubec, J., Greef, E. & Kool, H. J. 1982 Mutagenic activity associated with by-products of drinking-water disinfection by chlorine, chlorine dioxide, ozone and UV-irradiation. *Environ. Health Perspect.* **45**, 197-205.

Table 1 Contribution of individual DBPs to the chromosomal aberration-inducing activity and the transformation-inducing activity in chlorinated water (Itoh & Echigo, 2008).

DBPs	Chromosomal aberration-inducing activity	Transformation-inducing activity (by the two-stage assay)	Experimental conditions
Chloroform	0.5%	0.9%	Humic acid solution chlorinated with Cl ₂ /TOC = 1.0.
DCA	0.8%	0.25%	
TCA	1.6%	0.25%	
MX	<0.1%	<0.1%	Chlorinated Lake Biwa water.
Bromate	<0.1%	—	Humic acid solution treated with ozone/chlorine sequential treatment. Br ⁻ in the humic acid solution; 37.5 mg/L.

Fig. 1. Contributions of DBPs to the mutagenicity of ozonated/chlorinated water.

The areas of ellipses suggest the strength of mutagenicity based on the results of chromosomal aberration test.

Fig. 2. Effect of ozonation on the chromosomal aberration-inducing activity in chlorinated water with Br⁻ (Echigo *et al.*, 2004).

Conditions: humic acid concentration, 750 mg C/L; Br⁻, 37.5 mg/L; reaction time, 1 day; temperature, 20°C; chlorine dose, 1500 mg Cl₂/L; pH, 7.0.

Fig. 3. Proposed change of the toxicity of chlorinated water (Itoh *et al.*, 2006).

The thickness of arrows show the strength of initiation activity and promotion activity. Changes of the thickness of arrows after the lapse of time indicate changes of initiation activity and promotion activity in the presence of residual chlorine.

Fig. 4. Estimated changes in the chromosomal aberration-inducing activity in drinking-water (Itoh *et al.*, 2007). DOC of raw water, 2.0 mg/L; DOC after rapid sand filtration, 1.1 mg/L; added disinfectant, 1.1 mg/L (disinfectant/DOC=1); assumed residual disinfectant concentrations, 0.1 and 0.4 mg/L.

Fig. 5. Components of the estrogenic effects in chlorinated drinking-water (Itoh *et al.*, 2009).